



Our Ref: 707654 Notice to Tenderers #4

CIIC / CALIBRE

Tereora College – Stage 1 Works

NOTICE TO TENDERERS NO. 4

Contract No: C41/16 Date: 27/07/2016

Tender Closing Date: 18/08/2016

Please acknowledge by return email at time of receipt and in a covering letter with your tender.

No.	Question / Query or Amendment	Response, Clarification or Change
4.1	<i>Low voltage installation to Admin & Library building – please confirm that the mains cable is 6 x 240mm2...</i>	Yes. Respondents are to price as specified: 6x sets 240mm2 4C XLPE/PVC copper cable + 95mm2 earthing conductor from existing substation to MSB
4.2	<i>Administration Block: there are details showing Glass Walls on drawing A5.03, detail D10 and D13. Are these Glass Walls listed as windows:W115.01,W109.02,03,04,05,06?</i>	Yes. The glass block walls are W115.01, W109.02,03,04,05,06, (window type 8,9,10 and 11) on drawing A9.01.
4.3	<i>The schedule of quantities, section 6 Structural steel, refers to 'Approved primer'. Please confirm if the non-exposed fabricated structural steel has a primer finish?</i>	Yes. The non-exposed structural steel shall have a primer finish.
4.4	<i>Will the Fire Services (alarms, detectors, extinguishers, hydrants etc) be installed by others?</i>	Yes. The fire service devices/fixtures are not part of the scope of works of this RFT.