



Our Ref: 707654 Notice to Tenderers #8

**CIIC / CALIBRE**

## **Tereora College – Stage 1 Works**

### **NOTICE TO TENDERERS NO. 8**

**Contract No:** C41/16

**Date:** 17/08/2016

**Tender Closing Date:** 25/08/2016

Please acknowledge by return email at time of receipt and in a covering letter with your tender.

<b>No.</b>	<b>Question / Query or Amendment</b>	<b>Response, Clarification or Change</b>
8.1	<i>Hot dip galvanised and primer finish</i>	<p>Hot dip galvanised (HDG) steelwork is specified in the structural designs and specifications. A primer finish is only required where a Respondent proposes bare metal in place of HDG.</p> <p>The 'primer finish' sections in the schedule of quantities should be filled in where bare metal is proposed, otherwise left blank where HDG will be used.</p> <p>It is the Respondents responsibility when submitting a Conforming Tender to ensure the alternative (i.e. bare metal with primer finish) meets the performance standards of the materials specified in the designs and specifications. Such alternatives shall not form part of the Contract until approval to the alternative is given by the Engineer.</p>