


### FOOTPATH



### HEAVY DUTY FOOTPATH

#### NOTES

1. Refer to Auckland Transport Standard Detail Drawings for the following details :-  
Pram Crossings – Plan No. FP009  
Kerbs and Channels – Refer to Drawing Set GD000
2. Minimum footpath width is 1800mm. Maximum footpath width is 3000mm
3. All Services Lids must be raised or lowered to be flush with footpath levels.
4. Concrete to have minimum compressive strength of 20MPa at 28th day unless otherwise specified by the relevant AT Engineer
5. Basecourse (or bedding) layer depth must be increased for weak subgrade (CBR<3). As directed by the relevant AT engineer
6. Concrete surface finish must comply with NZS 3114 and AS/NZS 3661 Slip resistance of Pedestrian Surfaces

REVISION	BY	DATE



AUCKLAND TRANSPORT  
CODE OF PRACTICE

TITLE

CONCRETE FOOTPATH

SCALE:

N.T.S.

DRAWING No.

FP001

VERSION

4.0