



Trench Section Details  
within Road Corridor

NOTES:

1. GENERAL FILL TO BE WELL GRANTED GRANULAR MATERIAL. MAX PARTICAL SIZE 75mm.
2. GAP 40 BASECOURSE & GAP 65 SUB BASE WITH CONTROLLED GRADING & CRUSHING RESISTANCE.
3. CAOMPACTION IN LAYERS NOT EXCEEDING 200mm (COMPACTED THICKNESS)
4. TESTING TO SPECIFICATION REQUIREMENTS. APPLIES WHERE IN THE CARRIAGEWAY INCLUDING ROAD SHOULDER
5. REFER TO ICI FOR REQUIREMENTS & PROCEDURE WORKING WITHIN THE ROAD CORRIDOR

Appendix 6.



POWERING  
THE  
FUTURE

AMENDMENT

TITLE:

HV Cable Trench  
Specification

SCALE:

N T S

Plan No.

DRAWN BY:

DATE: