



Cook Islands Investment Corporation

Contract for Sports Arena Roller Doors and Steel Works

NOTICE TO TENDERERS NO. 1

Tender Reference: CK181931

Date of notice:

6/06/2019

Tender Closing Date: 18/06/2019

Please acknowledge receipt in A1 Form of Tender.

No.	Question / Query or Amendment	Response, Clarification or Change
1.1	Required samples Reference: RFT document pg 16, 6. <i>Samples.</i>	Tenderers must allow for providing finishing colour samples for the wall paint and finishing coating system for the steel. No other samples are required.
1.2	Aluminium frames for doors & windows Reference: <ul style="list-style-type: none">RFT document pg 14, 4. <i>Design responsibility, design submission procedures and acceptance criteria</i>Attachment 5, <i>Sheet 204 Door & Window Schedule.</i>	Tenderers must note that the aluminium frames for doors and windows must meet the wind load pressures and watertightness requirements as stated in the Scope (RFT pg 14, section 4.2 a.3). This takes precedence over the 'standard aluminium (residential)' frame stated in the drawings (Sheet 204 Door & Window Schedule).
1.3	Door and window details Reference: RFT Attachment 5, <i>Sheet 203 Details</i>	Tenderers must allow for the appropriate door and window head, sill and jamb to suit the tenderers proposed aluminium frames. Also note 1.2 above. The successful tenderer must show its proposed details in the shop drawings.
1.4	Aluminium screens Reference: RFT Attachment 5, <i>Sheet 202 Typical Wall Elevation</i>	With reference to the <i>Aluminium Security Screen & Insect Mesh</i> shown on Sheet 202 Typical Wall Elevation, Tenderers shall allow for a heavy duty 7mm aluminium diamond pattern grill system complete with woven insect mesh screen and aluminium frame. Aluminium grill and frames are to be powder-coated white. The woven insect mesh is to be in black or grey colour.
1.5	Internal plywood cladding Reference: RFT Attachment 5, <i>Sheet 203 Details</i>	Tenderers must allow to supply and install H3.1 LOSP treated plywood, in AB, AC or AD grade, for the internal cladding. The exposed face (A) shall have a clear coat/varnish finish.
1.6	General notes on drawings Reference: RFT Attachment 5, <i>Sheet 203 Details</i> and <i>Sheet 204 Door & Window Schedule</i>	Tenderers are to ignore the general notes numbered 3 to 5 on Drawing sheets 203 Details and 204 Door & Window Schedule. These do not apply to this Contract.