



17/06/19

Name of Tenderer

Our ref: 513314105:
NTT004

Dear Sir

Contract No. CK181930 – Access Road Maintenance Contractor Panel
Notice to tenderers number: NTT004

SCHEDULE ITEM D1.2.3

- 1) Q: The scope on item "D1.2.3 Supply unreinforced concrete" and couldn't find any parameters for the unreinforced concrete. Does it require boxing, What MPa is the concrete?
A: *The supply is for mass concrete only with no formwork. If formwork is required it will be identified and priced separately. The concrete strength to be allowed for in the price shall be MPa 25 N/mm².*

Yours Sincerely

A handwritten signature in blue ink that reads 'M Smith'.

MARTIN SMITH
Project Manager
Te Mato Vai (Cook Islands Water Partnership)
Rarotonga Water Supply Upgrade Project